


DRIVEWAY PERMIT REQUIREMENTS

All driveways shall have a minimum approach width of not less than twenty-six (26) feet at road edge, or culvert if need. There shall be at least eight (8) feet of gravel from the roadway not less than four (4) inches deep and a cleared passable driveway of not less than twenty (20) feet in width to provide for the passage of fire suppression equipment and ambulances.



TOWN OF NECEDAH TAXPAYERS

Please be aware that Ambulances and Fire Apparatus must have at least 12 feet of clearance from the ground up. This clearance will need to be maintained to the full length and width of the driveway. Trees and other obstructions could prevent the EMS and Fire Personnel from responding in a timely manner and could cause severe damage to emergency vehicles. There should be a cleared passable driveway of not less than twenty (20) feet in width to provide for the passage of fire suppression equipment and ambulances.